

55
15

----- AUTOLEAK REPORT -----
MON MAY 05,14 12:00:00 AM
STATION NAME:
SOLDOTNA Y CHEVRON
44024 STERLING HWY
SOLDOTNA AK 99669

TANK 1 PRODUCT: KEROSENE

LEAK RATE: -0.010 gal/hr
PASS 0.2 GPH TEST

LEAK TEST START:
THU MAY 01,14 12:00:00 AM
TEST 1: -0.010 gal/hr
TEST 2: ???? gal/hr
TEST 3: ???? gal/hr
TEST 4: ???? gal/hr
TEST 5: ???? gal/hr
TEST 6: ???? gal/hr

LEAK TEST END:
MON MAY 05,14 12:00:00 AM

TANK 2 PRODUCT: PREM UNLEAD

LEAK RATE: -0.026 gal/hr
PASS 0.2 GPH TEST

LEAK TEST START:
THU MAY 01,14 12:00:00 AM
TEST 1: -0.026 gal/hr
TEST 2: ???? gal/hr
TEST 3: ???? gal/hr
TEST 4: ???? gal/hr
TEST 5: ???? gal/hr
TEST 6: ???? gal/hr

LEAK TEST END:
MON MAY 05,14 12:00:00 AM

TANK 3 PRODUCT: DIESEL 4

LEAK RATE: 0.003 gal/hr
PASS 0.2 GPH TEST

LEAK TEST START:
THU MAY 01,14 12:00:00 AM
TEST 1: 0.003 gal/hr
TEST 2: ???? gal/hr
TEST 3: ???? gal/hr
TEST 4: ???? gal/hr
TEST 5: ???? gal/hr
TEST 6: ???? gal/hr

LEAK TEST END:
MON MAY 05,14 12:00:00 AM

TANK 4 PRODUCT: UNLEADED

LEAK RATE: -0.066 gal/hr
PASS 0.2 GPH TEST

LEAK TEST START:
THU MAY 01,14 12:00:00 AM
TEST 1: -0.066 gal/hr
TEST 2: ???? gal/hr
TEST 3: ???? gal/hr
TEST 4: ???? gal/hr
TEST 5: ???? gal/hr
TEST 6: ???? gal/hr

LEAK TEST END:
MON MAY 05,14 12:00:00 AM

----- AUTOLEAK REPORT -----
THU JUN 05,14 12:00:01 AM
STATION NAME:
SOLDOTNA Y CHEVRON
44024 STERLING HWY
SOLDOTNA AK 99669

TANK 1 PRODUCT: KEROSENE

LEAK RATE: -0.002 gal/hr
PASS 0.2 GPH TEST

LEAK TEST START:
TUE JUN 03,14 2:06:53 AM
TEST 1: -0.002 gal/hr
TEST 2: ???? gal/hr
TEST 3: ???? gal/hr
TEST 4: ???? gal/hr
TEST 5: ???? gal/hr
TEST 6: ???? gal/hr

LEAK TEST END:
THU JUN 05,14 12:00:00 AM

TANK 2 PRODUCT: PREM UNLEAD

LEAK RATE: -0.025 gal/hr
PASS 0.2 GPH TEST

LEAK TEST START:
TUE JUN 03,14 2:06:53 AM
TEST 1: -0.025 gal/hr
TEST 2: ???? gal/hr
TEST 3: ???? gal/hr
TEST 4: ???? gal/hr
TEST 5: ???? gal/hr
TEST 6: ???? gal/hr

LEAK TEST END:
THU JUN 05,14 12:00:00 AM

TANK 3 PRODUCT: DIESEL 4

LEAK RATE: 0.003 gal/hr
PASS 0.2 GPH TEST

LEAK TEST START:
TUE JUN 03,14 2:06:53 AM
TEST 1: 0.003 gal/hr
TEST 2: ???? gal/hr
TEST 3: ???? gal/hr
TEST 4: ???? gal/hr
TEST 5: ???? gal/hr
TEST 6: ???? gal/hr

LEAK TEST END:
THU JUN 05,14 12:00:00 AM

TANK 4 PRODUCT: UNLEADED

LEAK RATE: -0.020 gal/hr
PASS 0.2 GPH TEST

LEAK TEST START:
TUE JUN 03,14 2:06:53 AM
TEST 1: -0.020 gal/hr
TEST 2: ???? gal/hr
TEST 3: ???? gal/hr
TEST 4: ???? gal/hr
TEST 5: ???? gal/hr
TEST 6: ???? gal/hr

LEAK TEST END:
THU JUN 05,14 12:00:00 AM